

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No.F.6 DFS/MS/School/2021/SZ/ 697

Dated: 21/9/2021

**FIRE SAFETY CERTIFICATE**

Certified that the Delhi Police Public School, B-4, Safdarjung Enclave, New Delhi 110029 comprised of Basement, Ground plus Three Upper Floors (one block) and Ground plus Two upper floor (one block) was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2018/SZ/2463 Dated 01/11/2018. The said premises was re-inspected by officer concerned of this department on 25/08/2021 in presence of SI Salim (Admin Officer) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational Building Group - B" with effect from 21/9/2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 21/9/2021 at New Delhi by



**(SUNIL CHAWDHARY)  
DY. CHIEF FIRE OFFICER (SZ)  
DELHI FIRE SERVICE**

Copy to: -

1. The Principal, Delhi Police Public School, B-4, Safdarjung Enclave, New Delhi 110029
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."



**Principal  
Delhi Police Public School  
B-4, Safdarjung Enclave,  
New Delhi - 110029**